

## CERTIFICATE OF ANALYSIS

**Client:** Coastal Environmental  
721 Flittertown Rd  
Hammonton NJ 08037

**Report Date:** 4/18/2017  
**Report No.:** 533774 - Lead Water  
**Project:** Millbridge-Initial  
**Project No.:** Delran SD-LIW

**Client:** COA212

### LEAD WATER SAMPLE ANALYSIS SUMMARY

**Lab No.:**6198504                      **Location:**Boiler Room                      **Result(ppb):**<2.00  
**Client No.:**1-MB-POE

**Lab No.:**6198505                      **Location:**Hall Near Main Office                      **Result(ppb):**<2.00  
**Client No.:**2-MB-DW-POU

**Lab No.:**6198506                      **Location:**Main Office Copy Room                      **Result(ppb):**2.20  
**Client No.:**3-MB-DW

**Lab No.:**6198507                      **Location:**Faculty Room                      **Result(ppb):**<2.00  
**Client No.:**4-MB-TL

**Lab No.:**6198508                      **Location:**Room 400                      **Result(ppb):**<2.00  
**Client No.:**6-MB-DW

**Lab No.:**6198509                      **Location:**Room 401                      **Result(ppb):**<2.00  
**Client No.:**7-MB-DW

**Lab No.:**6198510                      **Location:**Hall Near 401                      **Result(ppb):**4.30  
**Client No.:**8-MB-DW

**Lab No.:**6198511                      **Location:**Room 402                      **Result(ppb):**6.60  
**Client No.:**9-MB-DW

**Lab No.:**6198512                      **Location:**Multi Purpose Rm Gym L                      **Result(ppb):**<2.00  
**Client No.:**10-MB-DW

**Lab No.:**6198513                      **Location:**Multi Purpose Rm Gym R                      **Result(ppb):**<2.00  
**Client No.:**11-MB-DW

Please refer to the Appendix of this report for further information regarding your analysis.

**Date Received:** 4/8/2017

**Date Analyzed:** 04/17/2017

**Signature:** 

**Analyst:** Mark Stewart

**Approved By:** 

Frank E. Ehrenfeld, III  
Laboratory Director

## CERTIFICATE OF ANALYSIS

**Client:** Coastal Environmental  
721 Flittertown Rd  
Hammonton NJ 08037

**Report Date:** 4/18/2017  
**Report No.:** 533774 - Lead Water  
**Project:** Millbridge-Initial  
**Project No.:** Delran SD-LIW

**Client:** COA212

### LEAD WATER SAMPLE ANALYSIS SUMMARY

**Lab No.:**6198514                      **Location:**Room 403                      **Result(ppb):**<2.00  
**Client No.:**12-MB-DW

**Lab No.:**6198515                      **Location:**Room 404                      **Result(ppb):**<2.00  
**Client No.:**13-MB-DW

**Lab No.:**6198516                      **Location:**Room 405                      **Result(ppb):**<2.00  
**Client No.:**14-MB-DW

**Lab No.:**6198517                      **Location:**Kitchen Sink 1                      **Result(ppb):**<2.00  
**Client No.:**15-MB-FP

**Lab No.:**6198518                      **Location:**Kitchen Food Prep Kettle                      **Result(ppb):**12.1  
**Client No.:**16-MB-FP

**Lab No.:**6198519                      **Location:**Cafeteria Ice                      **Result(ppb):**<2.00  
**Client No.:**17-MB-IM

**Lab No.:**6198520                      **Location:**Cafeteria Fountain L                      **Result(ppb):**<2.00  
**Client No.:**18-MB-WC

**Lab No.:**6198521                      **Location:**Cafeteria Fountain R                      **Result(ppb):**<2.00  
**Client No.:**19-MB-WC

**Lab No.:**6198522                      **Location:**Library Break Rm                      **Result(ppb):**21.4  
**Client No.:**20-MB-DW

**Lab No.:**6198523                      **Location:**Room 300                      **Result(ppb):**<2.00  
**Client No.:**21-MB-DW

Please refer to the Appendix of this report for further information regarding your analysis.

**Date Received:** 4/8/2017

**Date Analyzed:** 04/17/2017

**Signature:** 

**Analyst:** Mark Stewart

**Approved By:** 

Frank E. Ehrenfeld, III  
Laboratory Director

## CERTIFICATE OF ANALYSIS

**Client:** Coastal Environmental  
721 Flittertown Rd  
Hammonton NJ 08037


**Report Date:** 4/18/2017  
**Report No.:** 533774 - Lead Water  
**Project:** Millbridge-Initial  
**Project No.:** Delran SD-LIW


**Client:** COA212

### LEAD WATER SAMPLE ANALYSIS SUMMARY

<b>Lab No.:</b> 6198524 <b>Client No.:</b> 22-MB-DW	<b>Location:</b> Room 301	<b>Result(ppb):</b> 2.40
<b>Lab No.:</b> 6198525 <b>Client No.:</b> 23-MB-DW	<b>Location:</b> Room 302	<b>Result(ppb):</b> <2.00
<b>Lab No.:</b> 6198526 <b>Client No.:</b> 24-MB-DW	<b>Location:</b> Room 303	<b>Result(ppb):</b> <2.00
<b>Lab No.:</b> 6198527 <b>Client No.:</b> 25-MB-DW	<b>Location:</b> Room 304	<b>Result(ppb):</b> <2.00
<b>Lab No.:</b> 6198528 <b>Client No.:</b> 26-MB-DW	<b>Location:</b> Room 305	<b>Result(ppb):</b> <2.00
<b>Lab No.:</b> 6198529 <b>Client No.:</b> 27-MB-DW	<b>Location:</b> Room 306	<b>Result(ppb):</b> <2.00
<b>Lab No.:</b> 6198530 <b>Client No.:</b> 28-MB-DW	<b>Location:</b> Room 307	<b>Result(ppb):</b> <2.00
<b>Lab No.:</b> 6198531 <b>Client No.:</b> 29-MB-DW	<b>Location:</b> Room 308	<b>Result(ppb):</b> <2.00
<b>Lab No.:</b> 6198532 <b>Client No.:</b> 30-MB-DW	<b>Location:</b> Room 309	<b>Result(ppb):</b> <2.00
<b>Lab No.:</b> 6198533 <b>Client No.:</b> 31-MB-WS	<b>Location:</b> Rm A-05 Nurse	<b>Result(ppb):</b> <2.00

Please refer to the Appendix of this report for further information regarding your analysis.

**Date Received:** 4/8/2017  
**Date Analyzed:** 04/17/2017  
**Signature:**   
**Analyst:** Mark Stewart

**Approved By:**   
Frank E. Ehrenfeld, III  
Laboratory Director

## CERTIFICATE OF ANALYSIS

**Client:** Coastal Environmental  
721 Flittertown Rd  
Hammonton NJ 08037

**Report Date:** 4/18/2017  
**Report No.:** 533774 - Lead Water  
**Project:** Millbridge-Initial  
**Project No.:** Delran SD-LIW

**Client:** COA212

### LEAD WATER SAMPLE ANALYSIS SUMMARY

**Lab No.:**6198534                      **Location:**Room 200                      **Result(ppb):**<2.00  
**Client No.:**32-MB-DW

**Lab No.:**6198535                      **Location:**Room 201                      **Result(ppb):**<2.00  
**Client No.:**33-MB-DW

**Lab No.:**6198536                      **Location:**Room 202                      **Result(ppb):**<2.00  
**Client No.:**34-MB-DW

**Lab No.:**6198537                      **Location:**Room 203                      **Result(ppb):**<2.00  
**Client No.:**35-MB-DW

**Lab No.:**6198538                      **Location:**Room 204                      **Result(ppb):**2.10  
**Client No.:**36-MB-DW

**Lab No.:**6198539                      **Location:**Room 205                      **Result(ppb):**<2.00  
**Client No.:**37-MB-DW

**Lab No.:**6198540                      **Location:**Hall Near 206                      **Result(ppb):**<2.00  
**Client No.:**38-MB-DW

**Lab No.:**6198541                      **Location:**Room 206                      **Result(ppb):**7.80  
**Client No.:**39-MB-DW

**Lab No.:**6198542                      **Location:**Room 207                      **Result(ppb):**<2.00  
**Client No.:**40-MB-DW

**Lab No.:**6198543                      **Location:**Room 208                      **Result(ppb):**<2.00  
**Client No.:**41-MB-DW

Please refer to the Appendix of this report for further information regarding your analysis.

**Date Received:** 4/8/2017

**Date Analyzed:** 04/17/2017

**Signature:** 

**Analyst:** Mark Stewart

**Approved By:** 

Frank E. Ehrenfeld, III  
Laboratory Director

## CERTIFICATE OF ANALYSIS

**Client:** Coastal Environmental  
721 Flittertown Rd  
Hammonton NJ 08037

**Report Date:** 4/18/2017  
**Report No.:** 533774 - Lead Water  
**Project:** Millbridge-Initial  
**Project No.:** Delran SD-LIW

**Client:** COA212

### LEAD WATER SAMPLE ANALYSIS SUMMARY

**Lab No.:**6198544                      **Location:**Room 209                      **Result(ppb):**<2.00  
**Client No.:**42-MB-DW

**Lab No.:**6198545                      **Location:**Room 210                      **Result(ppb):**2.40  
**Client No.:**43-MB-DW

**Lab No.:**6198546                      **Location:**Room 211                      **Result(ppb):**<2.00  
**Client No.:**44-MB-DW

**Lab No.:**6198547                      **Location:**Hall Near Room 211                      **Result(ppb):**<2.00  
**Client No.:**44A-MB-DW

**Lab No.:**6198548                      **Location:**Room 212                      **Result(ppb):**<2.00  
**Client No.:**45-MB-DW

**Lab No.:**6198549                      **Location:**Room 100                      **Result(ppb):**<2.00  
**Client No.:**46-MB-DW

**Lab No.:**6198550                      **Location:**Room 101                      **Result(ppb):**<2.00  
**Client No.:**47-MB-DW

**Lab No.:**6198551                      **Location:**Room 102                      **Result(ppb):**<2.00  
**Client No.:**48-MB-DW

**Lab No.:**6198552                      **Location:**Room 104                      **Result(ppb):**<2.00  
**Client No.:**49-MB-DW

**Lab No.:**6198553                      **Location:**Room 103                      **Result(ppb):**<2.00  
**Client No.:**50-MB-DW

Please refer to the Appendix of this report for further information regarding your analysis.

**Date Received:** 4/8/2017

**Date Analyzed:** 04/17/2017

**Signature:** 

**Analyst:** Mark Stewart

**Approved By:** 

Frank E. Ehrenfeld, III  
Laboratory Director

## CERTIFICATE OF ANALYSIS

**Client:** Coastal Environmental  
721 Flittertown Rd  
Hammonton NJ 08037

**Report Date:** 4/18/2017  
**Report No.:** 533774 - Lead Water  
**Project:** Millbridge-Initial  
**Project No.:** Delran SD-LIW

**Client:** COA212

### LEAD WATER SAMPLE ANALYSIS SUMMARY

**Lab No.:**6198554                      **Location:**Room 106                      **Result(ppb):**<2.00  
**Client No.:**51-MB-DW

**Lab No.:**6198555                      **Location:**Room 105                      **Result(ppb):**<2.00  
**Client No.:**52-MB-DW

**Lab No.:**6198556                      **Location:**Room 108                      **Result(ppb):**<2.00  
**Client No.:**53-MB-DW


**Lab No.:**6198557                      **Location:**Room 107                      **Result(ppb):**<2.00  
**Client No.:**54-MB-DW


**Lab No.:**6198558                      **Location:**Room 110                      **Result(ppb):**<2.00  
**Client No.:**55-MB-DW

**Lab No.:**6198559                      **Location:**Hallway-CSI-(L)                      **Result(ppb):**<2.00  
**Client No.:**56-MB-WC

**Lab No.:**6198560                      **Location:**Hallway-CSI-(L)                      **Result(ppb):**<2.00  
**Client No.:**57-MB-WC

Please refer to the Appendix of this report for further information regarding your analysis.

**Date Received:** 4/8/2017  
**Date Analyzed:** 04/17/2017  
**Signature:**   
**Analyst:** Mark Stewart

**Approved By:**   
Frank E. Ehrenfeld, III  
Laboratory Director

---

## CERTIFICATE OF ANALYSIS

---

**Client:** Coastal Environmental  
721 Flittertown Rd  
Hammonton NJ 08037

**Report Date:** 4/18/2017  
**Report No.:** 533774 - Lead Water  
**Project:** Millbridge-Initial  
**Project No.:** Delran SD-LIW

**Client:** COA212

---

### LEAD WATER SAMPLE ANALYSIS SUMMARY

---

**Lab No.:**6198597  
**Client No.:**Blank


**Location:**Blank


**Result(ppb):**<2.00

---

Please refer to the Appendix of this report for further information regarding your analysis.

---

**Date Received:** 4/8/2017  
**Date Analyzed:** 04/17/2017  
**Signature:**   
**Analyst:** Mark Stewart

**Approved By:**   
Frank E. Ehrenfeld, III  
Laboratory Director

## CERTIFICATE OF ANALYSIS

**Client:** Coastal Environmental  
721 Flittertown Rd  
Hammonton NJ 08037

**Report Date:** 4/18/2017  
**Report No.:** 533774 - Lead Water  
**Project:** Millbridge-Initial  
**Project No.:** Delran SD-LIW

**Client:** COA212

### Appendix to Analytical Report:

**Customer Contact:** Cathy Ledden  
**Analysis:** AAS-GF - ASTM D3559-08D, USEPA 40CFR 141.11B, 2010

This appendix seeks to promote greater understanding of any observations, exceptions, special instructions, or circumstances that the laboratory needs to communicate to the client concerning the above samples. The information below is used to help promote your ability to make the most informed decisions for you and your customers. Please note the following points of contact for any questions you may have.

**iATL Customer Service:** customerservice@iatl.com  
**iATL Office Manager:** cdavis@iatl.com  
**iATL Account Representative:** Shirley Clark  
**Sample Login Notes:** See Batch Sheet Attached  
**Sample Matrix:** Water  
**Exceptions Noted:** See Following Pages

#### General Terms, Warrants, Limits, Qualifiers:

General information about iATL capabilities and client/laboratory relationships and responsibilities are spelled out in iATL policies that are listed at [www.iATL.com](http://www.iATL.com) and in our Quality Assurance Manual per ISO 17025 standard requirements. The information therein is a representation of iATL definitions and policies for turnaround times, sample submittal, collection media, blank definitions, quantification issues and limit of detection, analytical methods and procedures, sub-contracting policies, results reporting options, fees, terms, and discounts, confidentiality, sample archival and disposal, and data interpretation.

iATL warrants the test results to be of a precision normal for the type and methodology employed for each sample submitted. iATL disclaims any other warrants, expressed or implied, including warranty of fitness for a particular purpose and warranty of merchantability. iATL accepts no legal responsibility for the purpose for which the client uses test results. Any analytical work performed must be governed by our Standard Terms and Conditions. Prices, methods and detection limits may be changed without notification. Please contact your Customer Service Representative for the most current information.

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA LAP LLC, or any agency of local, state or province governments nor of any agency of the U.S. government.

This report shall not be reproduced except in full, without written approval of the laboratory.

#### Information Pertinent to this Report:

Analysis by AAS Graphite Furnace:  
- ASTM D3559-08D, USEPA 40CFR 141.11B, 2010  
- USEPA 200.9Pb, AAS-GF, RL <2 ppb/sample  
- USEPA SW 846-7000B:7421 - Pb(AAS-GF, RL <2 ppb/sample)

Certification:  
- NYS-DOH No. 11021  
- NJDEP No. 03863

Regulatory limit for lead in drinking water is 15.0 parts per billion as cited in EPA 40 CFR 141.11 National Primary Drinking Water Regulations, Subpart B: Maximum contaminant levels for inorganic chemicals.

All results are based on the samples as received at the lab. iATL assumes that appropriate sampling methods have been used and that the data upon which these results are based have been accurately supplied by the client.

Sample results are not corrected for contamination by field or analytical blanks.

PPB = Parts per billion. 1 µg/L = 1 ppb MDL = 0.24 PPB Reporting Limit (RL) = 2.0 PPB

#### Disclaimers / Qualifiers:

There may be some samples in this project that have a "NOTE:" associated with a sample result. We use added disclaimers or qualifiers to inform the client about something that requires further explanation. Here is a complete list with highlighted disclaimers pertinent to this project. For a full explanation of these and other disclaimers, please inquire at [customerservice@iatl.com](mailto:customerservice@iatl.com).

Water Sample Turbidity greater than 1.0 NTU does not meet Federal and NJ State Primary & Secondary Drinking Water Standards.